

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration: Pressure transmitters **PC-29A, PC-29B, PC-29PA, PC-29PB, PC-29S, PC-29PS** and differential pressure transmitters **PR-29A, PR-29B, PR-29S**.

Manufacturer: **APLISENS S.A.,
ul. Morelowa 7,
03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Pressure transmitters **PC-29A, PC-29B, PC-29PA, PC-29B, PC-29S, PC-29PS** and differential pressure transmitters type **PR-29A, PR-29B, PR-29S** in all versions comply with directives:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A. The following standards were applied: EN 61326-1:2013, EN 61326-2-3:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied: EN IEC 63000:2018.

Pressure transmitters and differential pressure transmitters **PC-29A, PC-29B, PC-29PA, PC-29PB, PC-29S, PC-29PS, PR-29A, PR-29B, PR-29S** in intrinsically safe versions comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Transmitters in intrinsically safe versions are marked with the following certificate marking:

II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb

I M1 Ex ia I Ma

FTZU 10 ATEX 0295X

Certificate (Module B) was issued by Notified Body no.1026, Physical Technical Testing Institute, Pikartaska 1337/7, 716 07 Ostrava Radvanice.

The following standards were applied: EN IEC 60079-0:2018, EN 60079-11:2012, EN 50303:2000.

Notification of quality assurance is issued (Module D) by Notified Body no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 01.09.2022

Adam Żurawski
General Manager

